

From: [Tim Andrew](#)
To: [Planning Mail](#)
Subject: 18/00342/OUT
Date: 17 April 2018 09:37:17

Our comments re the above application would be:

Access would need to be provided to the site for Refuse collection vehicles up to 32 Tonnes GVW, with sufficient room to turn round and exit the site. Any roads would need to be built to adoptable highways standards, with each resident able to place bins out for collection at the boundary of their property, otherwise a communal collection point would need to be provided.

Thanks,

Tim.

Tim Andrew
Operational Services Manager (Waste and Recycling)