

Application: 18/00342/OUT Blyth – Bawtry Road

Please refer enquires to Ross Marshall, Flood Risk Management Team, Nottinghamshire County Council, ross.marshall@nottscc.gov.uk 0115 9774473

Current preliminary comments: No objections subject to the following:

- 1. The surface water drainage is dealt with inline with the Drainage Assessment submitted by TDi (ref TDi320) and dated March 2018.**
- 2. Details of how the SUDS features within the proposals will be managed and maintained for the lifetime of the development to be agreed preferably prior to any permissions being granted. This is to ensure the drainage system remains effective for the lifetime of the development.**